

Hillsborough Township Bureau of Fire Safety

www.hillsboroughfiredistrict.com

(908) 369-4313

CERTIFICATE OF SMOKE ALARM, CARBON MONOXIDE ALARM AND PORTABLE FIRE EXTINGUISHER COMPLIANCE (CSACMAPFEC)

FIRE EXTINGUISHER REQUIREMENTS

FIRE EXTINGUISHER MUST BE AN **ABC TYPE** WITH A **MINIMUM RATING OF 2A10BC** AND A MAXIMUM SIZE OF 10 POUNDS

FIRE EXTINGUISHER MUST BE TAGGED AND INSPECTED BY A FIRE EXTINGUISHER INSPECTION AGENCY CERTIFIED BY THE NJ DIVISION OF FIRE SAFETY **WITHIN ONE YEAR, OR HAVE A RECEIPT TAPED TO THE EXTINGUISHER SHOWING PROOF OF PURCHASE WITHIN ONE YEAR.**

FIRE EXTINGUISHER MUST BE HUNG USING HANGERS, OR IN BRACKETS SUPPLIED BY THE MANUFACTURER. TOP OF EXTINGUISHER MUST BE NO MORE THEN FIVE FEET ABOVE THE FLOOR.

FIRE EXTINGUISHER MUST BE HUNG WITHIN 10 FEET OF EACH KITCHEN, IN A VISIBLE, UNBLOCKED AREA, NEAR A ROOM EXIT OR TRAVEL WAY THAT PROVIDES AN ESCAPE ROUTE TO THE EXTERIOR

